

Week of: _____

Time of Testing	Bather Load *Max #	Total Cl (ppm)	Free Cl 3 - 5.0 ppm	Combined Cl** ≤ 0.5 ppm	pH 7.2 – 7.8	Pool Clarity & Temp ≤104°F/ 40°C	Total Alkalinity 80 -120 ppm Calcium Hardness 180 - 220 ppm Cyanuric Acid 30 - 50 ppm <i>Test these Weekly</i>	Remarks: Chemicals added (eg: Backwash Filter, Drain pool, Vacuum pool, Add make-up water, etc.)	Initial
Sun									
Mon									
Tues									
Wed									
Thurs									
Fri									
Sat									

*Maximum Bather load calculated on pool size
Comments:

**Combined Cl = Total Cl - Free Cl